

MIAMI-DADE FIRE RESCUE DEPARTMENT - INSPECTION REPORT



FIRE PREVENTION DIVISION
 9300 NW 41 STREET, MIAMI, FLORIDA 33178
 PHONE 786.331.4800 FAX 786.331.4801



PERMIT # 00121-00205

Permit Type: Education **Inspection Month:** October
Billing Address:
 Dade County Public Schools - DCPS
 1450 NE 2 AVE RM 602 MIAMI, FL 33132

Inspection Date: 10/29/2013
Inspector: JAVIER CAMPS
Inspector phone: (786) 336-6845

RESULT: Inspected / N.O.V. (30)

DCPS VAN E BLANTON ELEMENTARY
10327 NW 11 AVE
MIAMI, FL 33150

NOTICE OF VIOLATIONS AND ORDER TO CORRECT

The hazards noted are in violation of the Florida Fire Prevention Code and/or Miami-Dade County Code. Nothing in this report supersedes any previously written, still existing violations for this occupancy. You are ordered to comply with the corrective measures within the time prescribed.

Please Note: A life safety permit required by County Code# 14-53 to operate within Miami-Dade County will be issued upon correction of all outstanding violations and payment of fees assessed. **Failure to obtain the required Life Safety Permit will result in Enforcement Actions including fines, citations, liens and/or orders to cease and desist operation.**

APPEALS

Any person that believes they were incorrectly issued a violation or that the violation cited is not applicable to their occupancy classification or believes aggrieved by any action or decision of this code may appeal to the Miami-Dade County Fire Prevention and Safety Appeals Board by filing a written notice **within 15 days** of receiving the *Notice of Violation and Order to Correct*. The appeal request must be submitted in writing to the Secretary of the Board. Information on filing an appeal can be obtained on the web at: <http://www.miamidade.gov/fire/request-appeal.asp> or by calling 786-331-4820. Filing of a written notice of appeal shall not stay the effect of any such action or decision which is the subject to the appeal.
 Code of Miami-Dade County, Part III, Chapter 14, Section 14-48

Viol.	Inspection Date	Comply by Date	VIOLATION, CORRECTION & COMMENTS
1	8/25/13	10/7/12	<p>Violation: NFPA 101 7.1.10.1* General. Means of egress shall be continuously maintained free of all obstructions or impediments to full instant use in the case of fire or other emergency.</p> <p>Correction: Maintain the means of egress free of all obstructions or impediments to full instant use in the case of fire or other emergency.</p> <p>Comments: Re-bill: This violation has been re-created for the new inspection detail by the system batch job</p>
2	10/29/13	11/28/13	<p>Violation: NFPA 1 13.7.3.2.3.1 A complete record of the tests and operations of each system shall be kept until the next test and for 1 year thereafter. [72:4.5.3.1]</p> <p>Correction: Provide current fire alarm system inspection reports free of deficiencies or provide documentation of correction.</p> <p>Comments: LAST ANNUAL INSPECTION WAS JAN 2012.</p> <p>PANEL DOWN UPON ARRIVAL. F/A LOG BOOK SHOWS FIREWATCH IS IN EFFECT.</p>

CUSTOMER SIGN OFF

Title: Representative
 Name: KEVERETTE WELLS