

PUBLIC PRIVATE SCHOOL

STATE OF FLORIDA DEPARTMENT OF HEALTH COUNTY HEALTH DEPARTMENT PUBLIC PRIVATE SCHOOL INSPECTION REPORT



Geocoded 25.870023/-80.215974

PURPOSE:
 ROUTINE
 CONSTRUCT.
 COMPLAINT
 QA SURVEY
 OTHER

REINSPECTION
 CHANGE OF OWNER
 CONSULTATION
 EPIDEMIOLOGY
 PREOPENING

TYPE: Public School

CENSUS	FEMALES	MALES
543	272	271

RESULTS:

Satisfactory
 Incomplete
 Unsatisfactory
OUT OF BUSINESS

Correct Violations by
 Next Inspection
 8:00 AM on

NAME Van E. Blanton Elem.
ADDRESS 10327 NW 11 Avenue **CITY** Miami
OWNER M-DCSB **ZIP** 33150
PERSON IN CHARGE Tangela Gore **PHONE** (305) 696-9211
E-MAIL tangela@dadeschools.net

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
13:15	14:00	09/09/2013	27357	13-51-08334

RE-INSPECTION DATE

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

SCHOOL SANITATION

- 1. School Site
- 2. Playground Equipment
- 3. Athletic Equipment

SANITARY FACILITIES

- 8. Natural Ventilation
- 9. Mechanical Ventilation
- 10. Provided/Accessible
- 11. Cleanliness & Repair
- 12. Toilet Facilities
- 13. Separation of Sexes
- 14. Fixture Ratio

WATER SUPPLY

- 15. Handwash Facilities
- 16. Showers/Fixtures
- 17. Shower Water Temp.
- 18. Installed/Operated/Maintained
- 19. Drinking Fountains
- 20. Approved Source

LIQUID/SOLID WASTE

- 21. Sewage Disposal
- 22. Solid Waste

VECTOR/VERMIN CONTROL

- 23. Infestation/Control
- 24. Brush/Trash
- 25. Water Collection/Drainage

SAFETY

- 26. First Aid Kit

FOOD

- 27. Food Insp. Rpt.

OTHER

- 28.
- 29.

COMMENTS AND INSTRUCTIONS

Violation #5 Repair water faucet leak in Rm. 6.
Code Reference FAC: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

Violation #15 Repair out of order handsink in Boy's restroom 043 and Girl's restroom on 2nd floor.
Code Reference FAC: Handwash Facilities 64E-13.004(6)(b). Handwashing facilities shall be located within or adjoining each toilet room. Soap dispensers shall be provided at all wash basins and liquid or powdered soap shall be used. Individual towels, preferably paper shall be used. Use of common or public towels is prohibited. Hot-air hand drying devices

Violation #19 Repair out of order water fountain in Rm. 3003.
Code Reference FAC: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

INSPECTION CONDUCTED BY: Cynthia Campos PHONE: (305) 623-3587
 INSPECTION COND SIGNATURE: [Signature] PHONE: _____
 COPY OF REPORT RECEIVED BY: [Signature] DATE: 9/9/2013